

**Drinking Water Quality and Compliance  
Town Short Form – Annual Notice to Consumers**

*(Note: This short form may be used for communities or waterworks serving a population of less than 5000).*

**Introduction**

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister’s Order or Permit to Operate a waterworks. The following is a summary of the **Town of Rose Valley’s** water quality and sample submission compliance record for the **2017 calendar year**. This report was completed on June 26, 2018. Readers should refer to Water Security Agency’s Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department’s monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, “what is the significance of Selenium in a water supply”, more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	<u>24</u>	<u>26</u>	<u>0</u>

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	<u>0.77 - 1.32 mg/L</u>	<u>0.62 – 1.10 mg/L</u>	<u>24</u>	<u>26</u>	<u>100%</u>

**Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records- From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
<b>Free Chlorine Residual</b>	at least 0.1	<u>0.60 – 1.18 mg/L</u>	<u>365</u>	<u>NIL</u>

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.*

**Turbidity – From Water Treatment Plant Records**

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
<b>Turbidity</b>	<u>1.0</u>	<u>0.05 - 0.64 NTU</u>	<u>NIL</u>	<u>NTU</u>	<u>365</u>	<u>365</u>

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for SE’s Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on June 30, 2017. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit Maximum Acceptable Concentration (MAC) mg/l	Interim Limit Maximum Acceptable Concentration (IMAC) mg/l	Sample Results mg/L	Number of Samples Exceeding the Limit
Arsenic	0.010		0.00200	NIL
Barium	1.000		<0.00071	NIL
Boron		5.000	0.40000	NIL
Bromate	0.010		NR	NIL
Cadmium	0.005		<0.00015	NIL
Chlorate	1.000		NR	NIL
Chlorite	1.000		NR	NIL
Chromium	0.050		<0.00019	NIL
Fluoride (avg *)	1.500		<0.05000	NIL
Lead	0.010		0.00010	NIL
Nitrate (avg *)	45.000		<0.02000	NIL
Selenium	0.010		<0.00113	NIL
Uranium	0.020		<0.00011	NIL

\*Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.

#### Chemical – Trihalomethanes (THMs)

**Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs. The Town of Rose Valley's water supplies are derived from groundwater NOT under the influence of surface water therefore, sampling/analysis for THMs is not required or performed.**

#### General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results Average (mg/L)	Number of Samples Required	Number of Samples Submitted
Aluminum	No Guideline	0.00696	1	1
Alkalinity	<500	62.0	1	1
Phenol Alkalinity	No Guideline	0	1	1
Bicarbonate	No Guideline	76	1	1
Calcium	No Guideline	4	1	1
Carbonate	No Guideline	0	1	1
Chloride	<250	12.4	1	1
Conductivity	<2300 uS/cm	227 uS/cm	1	1

Parameter	Aesthetic Objectives * (mg/L)	Sample Results Average (mg/L)	Number of Samples Required	Number of Samples Submitted
Copper	1	0.0088	1	1
Hardness	<800	18	1	1
Hydroxide	No Guideline	0	1	1
Iron	<0.3	0.1	1	1
Magnesium	<200	2	1	1
Manganese	<0.05	<0.01	1	1
pH	6.5 - 9.0 pH units	7.8 pH units	1	1
Potassium	No Guideline	<1	1	1
Sodium	<300	41	1	1
Sulphate	<500	31.3	1	1
Total dissolved Solids	<1500	168	1	1
Zinc	<5	.0042	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in 2017 and submitted on **June 30, 2017**. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from:**

**Town of Rose Valley Box 460 Rose Valley, Saskatchewan S0E 1M0**

**Phone: 1-306-322-2232 Fax: 1-306-322-4461 email: [rosevalley@sasktel.net](mailto:rosevalley@sasktel.net)**

March 2008 EPB 236D